



**NOTES:**

1. RESTRAINT GLANDS AND TIE RODS REQUIRED FROM MAIN TO HYDRANT.
2. IF HYDRANT IS AT A DEAD END, TIE RODS MUST BE TAKEN TO JOINT OF FIRST FULL LENGTH OF PIPE.
3. ALL HYDRANTS TO OPEN RIGHT, (WATER VALVES OPEN LEFT).
4. SEE TYPICAL TRENCH DETAIL FOR BACKFILL REQUIREMENTS.

HYDRANT ASSEMBLY DETAIL

NOT TO SCALE